



Village of Clarendon Hills International Fire Code Amendments

(Commercial and Multi-Family Residential Only)

AMENDMENTS TO INTERNATIONAL FIRE CODE: The International Fire Code 2006 as adopted, effective January 1, 2007, is revised and amended as follows:

- (1) Section 101.1. Title. - Insert: "Village of Clarendon Hills"
- (2) Section 108. Means of Appeal. - Delete entire section.
- (3) Section 109.3. Violation penalties. - Delete entire section.
- (4) Section 901.6. - Add the following sentences to the section: "Inspections and field tests of fire suppression, alarm, detection and any other fire protection systems, devices and equipment shall be conducted by a licensed fire protection company representative. All tests for the fire protection systems and components shall follow the standards of this Code and the National Fire Protection Association standards for the type of component. Whenever any such fire protection company conducts tests or undertakes maintenance or repair work on any said systems within the Village, the company shall notify the Village's dispatch agency of all such tests, maintenance, or repair prior to undertaking them, and further, immediately after completion of such tests, maintenance, or repair, shall notify the Village's dispatch agency of such completion."
- (5) Section 901.6.2. Records. - Add the following sentence: "A copy of the complete written record of all tests and inspections required under this Code shall be sent to the Clarendon Hills Fire Prevention Bureau within ten (10) working days after completion of the test."
- (6) Section 903.2. Where required. - Replace the section in its entirety with the following: "Approved automatic sprinkler systems in new and existing buildings and structures shall be provided in the locations described in Section 24.10 Automatic Supervised Fire Protection Systems, and 21.17 Residential Sprinkler Systems, of the Village Code."